



DIMENSIONS SHOWN IN MILLIMETRES

NOTES:

EXTENDED ARMS FOR EXTENSION CORDS ARE PERMITTED WITH EACH INSTALLATION BEING APPROVED BY THE BUILDING INSPECTOR.

1. MINIMUM 2.6 m IN HEIGHT ABOVE THE ROADWAY OR 2.45 m ABOVE THE SIDEWALK, WHICH EVER PROVIDES THE HIGHER CLEARANCE ABOVE THE SIDEWALK.

2. EXTENDED ARM MUST ONLY PROTRUDE TO A MAXIMUM OF 0.3 m BEYOND THE STREET SIDE OF THE SIDEWALK, AND BE ABLE TO PIVOT INWARD TO BE AT LEAST PARALLEL WITH THE SIDEWALK.

3. UPRIGHT POST TO BE INSTALLED A MINIMUM 0.5 m BEHIND THE SIDEWALK OR AS SPECIFIED BY THE BUILDING INSPECTOR.

4. CORDS MUST BE SECURELY FASTENED TO OR LOCATED WITHIN THE ARM TO PREVENT PEDESTRIANS AND SNOW CLEARING EQUIPMENT FROM BECOMING ENTANGLED IN THE CORD.

5. THE ARM IS TO BE REMOVED BY MARCH 30th EACH YEAR, AND INSTALLED NO EARLIER THAN NOVEMBER 1st OF EACH YEAR.

6. WHEN CORDS ARE NOT BEING USED THE ARM MUST BE ROTATED AT LEAST PARALLEL TO THE SIDEWALK, AND THE CORD DE-ENERGIZED.

7. CORDS MUST BE CONNECTED TO A CSA APPROVED GROUND FAULT RECEPTACLE.

**CITY OF KENORA
STANDARDS FOR EXTENSION
CORDS OVER PUBLIC
WALKWAYS**

NOT TO SCALE

JANUARY 2006