

ADDENDUM

Project Name: City of Kenora Crawford Road Lift Station and Wastewater Treatment Plant Generator Replacements

Project No.: 412-004-25

Addendum No.: 2

Issued By: Z. A. McCarthy Engineering Services Ltd.

Date Issued: July 24, 2026

This addendum shall be incorporated into the tender/proposal submission and shall form a part of the contract documents.

ITEM NO.	DESCRIPTION
1	The time and date for Tender Closing is revised to: 11:00:00 a.m. CST/CDT on August 6, 2026
2	Section 00 21 13 Instructions to Tenderers shall be revised to include Section 9 Tender Deposit as follows: 9 TENDER DEPOSIT 9.1 The Tenderer is required to submit with its Tender, a Consent of Surety and a Bid Bond in a form acceptable to the CITY, or in lieu of a Bid Bond, a Tenderer may submit, along with a Consent of Surety, a certified cheque or an irrevocable letter of credit in favour of the CITY equal to 10% of the Tender Sum as a guarantee that, if awarded the contract for the Work, the Tenderer will execute a contract. 9.2 The Bid Bonds, certified cheques or irrevocable letters of credit of the unsuccessful Tenderers shall be returned as soon as possible after the Contract has been duly executed by the Successful Tenderer. 9.3 The CITY will not pay any interest on money furnished as security. 9.4 The Bid Bond and Consent of Surety shall be issued by a Surety Company licensed in the Province of Ontario and satisfactory to the CITY.

3	The following manufacturers are accepted for the equipment listed below: Generator Sets: Cummins, Rehlko, Caterpillar Automatic Transfer Switches: Cummins, Rehlko, ASCO Silencers: Cummins, VAW Exhaust Fans: Greenheck, Loren Cook Louvers: Price Industries, Ventex/Nailor Control Dampers: Tamco, Alumavent Manufacturer acceptance does not constitute approval of final equipment selections; final equipment shall be reviewed for conformance with the Contract Documents during the shop drawing review process.
4	All new fuel oil supply and return piping between existing fuel tanks and generator sets at both the Crawford Lift Station and Wastewater Treatment Plant as indicated on the drawings shall be revised as follows: Piping: 1. Ø½" Schedule 40 black steel pipe to ASTM A106 Gr B Fittings: 1. Forged steel socket welding type to ASME B16.11, wall thickness to match pipe, 2. Black malleable iron, bronze face, ground joint unions to ASME B16.39. Provide suitable piping supports as required and spaced in accordance with accepted industry practice and the requirements of CSA B139.

END OF ADDENDUM