



December 19, 2025

CITY OF KENORA

**TENDER #860-7888-2
McLeod Park Phase 2**

ADDENDUM No. 5

This Addendum is issued prior to tender closing, for the above captioned tender call.

The following modifications are hereby made a part of the Tender document and all of their effect is to be included in the tender prices.

Clarifications/Changes to Tender Documents:

- 1) Pergola height: the height of the pergola is based on existing conditions. The underside of the pergola is to be six (6) inches above the top of the existing washroom building. For tender purposes, the height of the existing building is approximately 118.5 inches. Final height is to be confirmed by the successful bidder prior to construction.