

**1. GENERAL**

**1.1 General**

- .1 This Addendum varies the Bidding and Contract Documents titled Pool Structural Support dated May 22, 2026.
- .2 This Addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein shall be included in the Contract sum. The following revisions supersede the information contained in the original specifications and drawings issued for the above-named project. Acknowledge receipt of this Addendum by inserting its number, date, and pages in Bid Form.
- .3 This Addendum is 3 pages in total including attachments which form a part of this Addendum.

**1.2 CONTRACT DOCUMENTS: GENERAL**

- .1 Apply a global change throughout Contract Documents to revise the project address from "8 Mike Richards Way" to "18 Mike Richards Way"

**1.3 Attachments**

- .1 The following documents are included in this addendum.

.1 Specifications:

Section No.	Section Title	No. of Pages
NA	Not Used.	NA

.2 Drawings:

Drawing No.	Description	Issue Date
NA	Not Used.	NA

.3 Other Documents:

Description	Issue Date	No. of Pages
Not Used.	NA	NA

**2. CHANGES TO ADDENDA**

- 2.1 Not used.

**3. ALTERNATIVE MATERIALS**

- 3.1 Not used.

**4. CHANGES TO PROJECT MANUAL**

- .1 Reference Specification "Instructions to Tenderers":
  - .1 Revise section 4, Bid Call Schedule

- .1 Modify the date for 4.1 "Deadline for Issuing Addenda" to "June 5th, 2026, 16:00 (CDT)".

## 5. CHANGES TO DRAWINGS - STRUCTURAL

### 5.1 Not used.

## 6. BIDDER QUESTIONS

- .1 Question: Does the contractor need any special licensing or inspection for the removal of the slide?
  - .1 Answer: No
- .2 Question: Does the contractor require licensing to install the water slide following repairs?
  - .1 Answer:
    - .1 Following completion of the mezzanine platform repairs, the Contractor shall be responsible for the reinstallation and attachment of the slide assembly to the repaired structure.
      - .1 The Contractor shall ensure that:
        - .1 The slide assembly attachment and any associated mechanical assembly work are performed by a qualified Red Seal Industrial Mechanic (Millwright) or an Ontario-certified Amusement Device Mechanic.
        - .2 Where a Red Seal Industrial Mechanic (Millwright) performs the work, it shall be carried out under the general supervision of an Ontario-certified Amusement Device Mechanic in accordance with applicable regulatory requirements.
        - .3 The supervising certified amusement device mechanic shall be consulted regarding the proposed attachment and assembly methodology prior to the work being undertaken.
        - .4 Copies of all relevant trade certifications, including the Millwright's Red Seal certification and the supervising mechanic's amusement device certification, shall be provided to the Owner before commencement of the slide reinstallation work.
        - .5 All work shall comply with applicable amusement device regulations, manufacturer requirements, and industry standards.
- .3 Question: Is the feature wall wood framed?
  - .1 Answer: The feature wall is CMU (concrete block).
- .4 Question: Has the City considered any methods to stop the corrosion in the concrete beam?
  - .1 Answer: Refer to repair details on drawings, product that contains an integrated corrosion inhibitor and anti-corrosion coating for the reinforcing surface have been specified.
- .5 Question: Does the work require a building permit?

- .1 Answer: Yes the work requires a building permit, The City of Kenora has applied for the building permit. Upon award of contract the contractor will be responsible for taking over the permit and coordinating inspections and closing out the permit.
- .6 Question: Does the contractor need to complete a Pre-Construction Hazardous Building Materials Assessment?
  - .1 Answer: No, the City will be responsible for completing and paying for the Pre-Construction Hazardous Building Materials Assessment
- .7 Question: Can you please advise what product you would like used a coating on the water slide structure?
  - .1 Answer: Refer to the repair notes on the drawing, product sample is provided. An approved equal may be allowed pending approval from the consultant before purchasing or applying an approved equal.

**END OF SECTION**